

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL
DIVISION OF AIR & WASTE MANAGEMENT
391 LUKENS DRIVE
NEW CASTLE, DELAWARE 19720-2774



WASTE MANAGEMENT SECTION
TANK MANAGEMENT BRANCH

TELEPHONE: (302) 395-2500
FAX No.: (302) 395-2555

January 1, 2005

John Doe
My Company
33 Any Street
This City USA

RE: My Station
33 Any Street
City USA

Facility ID#: 3-000000
Operating Permit #: APC-2005/0000.OII
File Code: 04A

Dear Mr. Doe

Pursuant to the Delaware's Regulations Governing the Control of Air Pollution, Regulation 2, Section 2, approval is hereby granted by the Department of Natural Resources and Environmental Control, Tank Management Branch (the Department) for the operation of the Hasstech VCP-2/2A Stage II Vapor Recovery System at the above-referenced facility.

This permit is issued subject to the following conditions:

1. This facility shall be in compliance with all the requirements of Regulation 24, Section 36, of Delaware's Regulations Governing the Control of Air Pollution.
2. The project must have been constructed in accordance with CARB Executive Order # G-70-7-AD (i.e. modification of the certification of the Hasstech Model VCP-2/2A Stage II Vapor Recovery System).

If you wish to make any changes to the system in the future you will need to reapply for a construction permit.

3. Representatives of the Department may inspect the facility at any reasonable time.
4. The maximum length of hose must be fourteen (14) feet.
5. The maximum dispensing rate for the Hasstech Model VCP-2/2A shall be ten (10) gallons per minute.
6. The Hasstech system shall be visually inspected daily for damage to hoses and nozzles and an inspection record maintained. The inspection records must be kept on file for at least three (3) years and organized chronologically.
7. Only Dual Point Stage I Vapor Recovery Systems may be used with the Hasstech Model VCP-2 and 2A Stage II Vapor Recovery Systems.

Delaware's good nature depends on you!
